

Applications of machine learning in diagnostics and prognostics of wind turbine generators

Alan Turnbull

Supervisors:

Dr. James Carroll (Strathclyde University)

Dr. Alasdair McDonald (Strathclyde University)


Contents

- Research motivations
- Overview of research
- Applications of machine learning in wind turbine condition monitoring
- Diagnostics & Prognostics - a case study using generator bearing failure
- Conclusions and future work

Motivation of research



- O&M can contribute significantly to overall LCOE
- Costs are expected to increase as wind farms are located further offshore
- Increasing reliability and optimising O&M becomes increasingly important
- As wind farms scale up the cost of specialist services will also increase
- Automation and big data analytics are key to driving down costs and addressing these issues

Why WT Generators?




Ref. [1]

Wind farm condition monitoring



Adapted from Ref. [2]


PhD Overview - Machine learning for fault diagnosis & prognosis



Gen DE bearing – RUL prediction

Methodology:

1. Determine diagnostics for possible generator bearing faults
2. Create database of failure examples
3. Analyse how diagnostics change leading up to failure
 - How different is fault progression between failures?
 - Can we identify 'end-of-life' indicators?
4. Feature engineering – what features influence baseline diagnostic level?
5. Label and group failure data
6. Train, validate and classification model
7. Use on new data to identify fault and RUL



Gen DE bearing – RUL prediction

Methodology:

1. Determine diagnostics for possible generator bearing faults
2. Create database of failure examples
3. Analyse how diagnostics change leading up to failure
 - How different is fault progression between failures?
 - Can we identify 'end-of-life' indicators?
4. Feature engineering – what features influence baseline diagnostic level?
5. Label and group failure data
6. Train, validate and classification model
7. Use on new data to identify fault and RUL

Data pool in numbers

7 wind farms

15 wind turbines


306 vibration samples (per sensor)

~ **10s** sample time with ~**25kHz** sample rate

Gen DE bearing – RUL prediction

Methodology:


1. Determine diagnostics for possible generator bearing faults
2. Create database of failure examples
3. Analyse how diagnostics change leading up to failure
 - How different is fault progression between failures?
 - Can we identify 'end-of-life' indicators?
4. Feature engineering – what features influence baseline diagnostic level?
5. Label and group failure data
6. Train, validate and classification model
7. Use on new data to identify fault and RUL



Gen DE bearing – RUL prediction


Methodology:

1. Determine diagnostics for possible generator bearing faults
2. Create database of failure examples
3. Analyse how diagnostics change leading up to failure
 - How different is fault progression between failures?
 - Can we identify 'end-of-life' indicators?
4. Feature engineering – what features influence baseline diagnostic level?
5. Label and group failure data
6. Train, validate and classification model
7. Use on new data to identify fault and RUL



Methodology:

1. Determine diagnostics for possible generator bearing faults
2. Create database of failure examples
3. Analyse how diagnostics change leading up to failure
 - How different is fault progression between failures?
 - Can we identify 'end-of-life' indicators?
4. Feature engineering – what features influence baseline diagnostic level?
5. Label and group failure data
6. Train, validate and classification model
7. Use on new data to identify fault and RUL



Gen DE bearing – RUL prediction

Methodology:

1. Determine diagnostics for possible generator bearing faults
2. Create database of failure examples
3. Analyse how diagnostics change leading up to failure
 - How different is fault progression between failures?
 - Can we identify 'end-of-life' indicators?
4. Feature engineering – what features influence baseline diagnostic level?
5. Label and group failure data
6. Train, validate and classification model
7. Use on new data to identify fault and RUL

Results

- **Diagnostics:** Correctly diagnosis of bearing fault with up to ~98% accuracy
- **Prognostics:** Correctly predicting failure within 1-2 months with up to ~86 % accuracy

Cluster 1


True class	Healthy	17 (77.2%)	3 (13.6%)
	Unhealthy	5 (22.8%)	19 (86.4%)
		Healthy	Unhealthy
		Predicted class	

Cluster 2

True class	Healthy	32 (76.2%)	8 (19%)
	Unhealthy	10 (23.8%)	34 (81%)
		Healthy	Unhealthy
		Predicted class	

Conclusions

- Machine learning can assist engineers in many aspects of condition monitoring including automated anomaly detection and fault classification
- Specialist engineering knowledge is fundamental to unlock this potential by understanding underlying component kinematics and fault diagnostics for feature engineering
- Improvements in prognostics requires more examples of components that have been run to failure to be made available, or more information about fault progression at the time of replacement – data that is lacking in academic research



Thank you for the attention, any questions?

References

- [1] P. Tchakoua, R. Wamkeue, M. Ouhrouche, F. Slaoui-Hasnaoui, T. A. Tameghe, and G. Ekemb, “Wind turbine condition monitoring: State-of-the-art review, new trends, and future challenges,” *Energies*, vol. 7, no. 4, pp. 2595–2630, 2014.
- [2] B. Hahn, M. Durstewitz, and K. Rohrig, “Reliability of wind turbines - experiences of 15 years with 1,500 wts,” *Wind Energy*, pp. 329–+, 2007.

futureWind 2020
 **& Marine**